



Declaration of Performance / Ydeevnedeklaration VELFAC 200 Energy WMA smoke

The performance of the Windows and Patio doors in the product serie VELFAC 200 Energy WMA smoke are in conformity with the declared in this document.
This declaration of performance is issued under the sole responsibility of VELFAC A/S.

Ydeevnen for Facadevinduer og Terrassedørene i produktserien VELFAC 200 Energy WMA smoke er i overensstemmelse med de deklarerede ydeevner i dette dokument.
Denne ydeevnedeklaration udstedes på eneansvar af VELFAC A/S.

Signed on behalf of VELFAC A/S:

Underskrevet på vegne af VELFAC A/S:

Finn Jespersen
CEO, Administrerende Direktør

Harmonised technical specification Harmoniseret teknisk specifikation	EN 12101-1
Type of construction product Byggevaretype	Windows and Patio doors Facadevinduer og Terrassedøre
Construction product identification Byggevareidentifikation	VELFAC 200 Energy WMA smoke
Intended use Byggevarens tilsigtede anvendelse	For domestic and commercial buildings Til boliger og erhvervsbygninger
Manufacturer Producent	VELFAC A/S
Manufacturer, address Producent, adresse	Bygholm Søpark 23, 8700 Horsens, Denmark
Name and address of authorised representative Navn og adresse på bemyndiget repræsentant	n/a
System of assessment and verification of constancy of performance of the construction product Systemerne for vurdering af kontrol af konstansen af byggevarens ydeevne	(AVCP) System 3
Notified Bodies / Notificerede organer	
SP Technical Research Institute of Sweden , Box 857, SE-501 15 Borås, Sweden	NB 0402

Declaration of Performance / Ydeevnedeklaration VELFAC 200 Energy WMA smoke

200E WMA smoke-01-CGR

	V201 Energy WMA smoke	V212 Energy WMA smoke	V231 Energy WMA smoke	V203 Energy WMA smoke						
Element type	Sidehung	Tophung projecting	Door high window	Buttomhung						
Opening direction	Outward	Outward	Outward	Outward						
Element type	Sidehængt	Topstyret	Vinduesdør	Bundhængt						
Åbningsretning	Udadgående	Udadgående	Udadgående	Udadgående						
4.4 Fire characteristics / Brandegenskaber	B300	B300	B300	B300						
Test and Classification / Test og klassifikation	En 12.101-2:2003	En 12.101-2:2003	En 12.101-2:2003	En 12.101-2:2003						
Notified body / notificeret organ	NB 0402	NB 0402	NB 0402	NB 0402						
Test report, issue date (element size) / Test rapport, udgivelsesdato, (element størrelse)	SP 4P01365-03-2 April 2014 (800x2475)	SP 4P01365-03-2 April 2014 (2200x780)	040L-CPR-SCO499-14 August 2014	040L-CPR-SCO499-14 August 2014						